

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
District Disaster Response & Fire Officer  
Andhra Pradesh, Nellore

To:  
(1) The Regional Joint Director, School  
Education, Govt of AP, (2) The District  
Educational Officer, SPSR Nellore District,

**File No: 30056/NLR/DFO/2026, Date:10/02/2026**

**Occupancy NoC RC Number: 9655/NLR/DFO/2019,Dt:27-09-2019 of the DFO,SPSR Nellore District**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Akshara Vidyalaya, represented by Smt Muppala Venkataraju Kumuda, Located at Saraswathi Nagar,Opp Jio Petrol Bunk, Venkatachalam(V&M),PIN-524320, SPSR Nellore District -** Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
  3. This Office NOC for Occupancy Rc No. 9655/NLR/DFO/2019,Dt:27-09-2019 of the DFO,SPSR Nellore District, Dt.27/09/2019
  4. Renewal NOC For Occupancy 9655/NLR/DFO/2019,Dt:27-09-2019 of the DFO,SPSR Nellore District, Dt.27/09/2020
  5. Online Application for Renewal NOC of Smt Muppala Venkataraju Kumuda, Located at Saraswathi Nagar,Opp Jio Petrol Bunk, Venkatachalam(V&M),PIN-524320, SPSR Nellore District - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 09-02-2026.

-- x --

The Management of Akshara Vidyalaya, represented by Smt Muppala Venkataraju Kumuda, Located at Saraswathi Nagar,Opp Jio Petrol Bunk, Venkatachalam(V&M),PIN-524320, SPSR Nellore District has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.67395/- vide challan No. 91290439172025, Dated 29/12/2025 at SBI, Through CFMS Challana.

**Akshara Vidyalaya Located at Saraswathi Nagar, Opp Jio Petrol Bunk,  
Venkatachalam(V&M),PIN-524320, SPSR Nellore District**

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Smt Muppala Venkataraju Kumuda Located at Saraswathi Nagar,Opp Jio Petrol Bunk, Venkatachalam(V&M),PIN-524320, SPSR Nellore District**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 10/02/2026 to 09/02/2029.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91290439172025	2025-12-29	67395

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

1. This Renewal NOC is issued form Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
2. The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection.
3. It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per GO.Ms.No:178, Home (Prisons & Fire), Dt:17-12-2025. two months before expire of this Renewal No Objection Certificate.
4. The Management shall submit the Declaration/Affidavit to this office as per Clause I.(B) (ii)(Liability to maintain Fire Safety Measures) of GO.Ms.No:218, Home (Prisons & Fire), Dt:22-12-2023 for every year during the renewal period or otherwise this No objection certificate deemed to be cancelled.



Your Sincerely,

*V. Suman Kumar*  
10/12/24

District Disaster Response & Fire Officer,  
Nellore District

Copy to Management Smt Muppala Venkataraju Kumuda, Akshara Vidyalaya Located at Saraswathi Nagar, Opp Jio Petrol Bunk, Venkatachalam(V&M),PIN-524320, SPSR Nellore District

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned